

**Customer name:**  
**Name:** PK elektronik Poppe GmbH  
**Address:** Ameisenweg 6, 16727 Velten  
**MUT SN:** 8200695345  
**Comment:** Zählerprüfung vor Ort

**Configuration:**  
**Firm. vr.:** 1.4.1      **U:** Direct (auto, auto, auto)      **PT:** 440000V/57.7V OFF  
**TE30 S/N:** 33358      **I:** CT100AC (auto, auto, auto)      **CT:** 6000A/5A OFF  
**Input Wiring:** 3 Phase 4 Wire      **C:** 10000 imp./kWh-  
**Power:** P

**Error test results : test4.rem**

Parameter	Value
C	10000 imp./kWh
t/N	10 s
Limit	1.000000 %
n	1
PT	440000V/57.7V OFF
CT	6000A/5A OFF

**Error test results : test4.rem**

Symbol	L1	L2	L3	L123
U	229.988 V	230.011 V	229.992 V	
Ud	398.361 V	398.345 V	398.393 V	
I	5.00115 A	5.00112 A	4.99923 A	
Phi	-0.005 deg	-0.019 deg	-0.011 deg	
PF	---	---	---	
sin	---	---	---	
tg_phi	---	---	---	
VPHI	---	120.007 deg	-120.011 deg	
P	---	---	---	3.45030 kW
Q	---	---	---	-701.528 mvar
S	---	---	---	3.45030 kVA
F	50.0004 Hz			
Rot	L123			
Un	0.00000 mV			
In	0.00000 mA			

No	Date	Time	Test type	Power type	Limit	Epsilon	EpsilonS	OK
1	2024-02-16	11:22:11	t	P	1.000	-0.338	0.002	Yes

